

Carroll County Water Resource Coordination Council

Hampstead * Manchester * Mt. Airy * New Windsor
Carroll County Health Department



* Sykesville * Taneytown * Union Bridge * Westminster
Carroll County Government

WRCC Meeting Summary July 26, 2023

Attendees:

Municipalities:

- Kevin Hann, Chair, Hampstead
- Jim Wieprecht, Vice Chair, Taneytown
- John Dick, Westminster
- Gary Dye, New Windsor
- Delbert Green, Manchester
- Mayor Perry Jones, Union Bridge
- Rodney Kuhns, Manchester
- Alex Perricone, Manchester
- Jim Roark, Hampstead
- Kevin Rubenstein, Sykesville
- Kevin Smeak, Taneytown
- Dick Swanson, Mount Airy

CC LRM:

- Brenda Dinne
- Glenn Edwards
- Chris Heyn, Director
- Claire Hirt
- Mary Lane
- Byron Madigan
- Kelly Martin
- Denise Mathias
- Zach Neal
- Janet O'Meara
- Ed Singer
- Price Wagoner

Health Department:

- Richard Brace

CCG Others:

- Andy Watcher, CC DPW
- Lydia Rogers, CC M&B
- Bryan Bokey, CC DPW

Guest Speakers:

- Phoebe Aron, Hazen
- Jeremy Hise, Hazen

Others:

- Joan White, City of Baltimore
- Paul Sayan, City of Baltimore
- Bill Felter, City of Baltimore

1. Opening Statement

Chair – Kevin Hann

Mr. Hann opened the meeting at 2:30 PM. He introduced Jim Roark, Acting Town Manager for Hampstead. All attendees introduced themselves.

Vice Chair – Jim Wieprecht

None.

2. Approval of Meeting Summary – June 28, 2023

Approval of the June meeting summary was discussed. No changes were made.

APPROVAL OF MINUTES: Motion was made by Alex Perricone and seconded by Dick Swanson to approve the June 28, 2023, meeting summary as written. Motion carried.

3. PFAS Implications for Municipalities – Phoebe Aron and Jeremy Hise, Hazen

- Phoebe Aron and Jeremy Hise with Hazen, the firm working on the Water Resources Element, presented an overview of the implications of PFAS (per-and polyfluoroalkyl substances) for the municipalities.
- EPA's proposed rule will set the maximum contaminant levels for PFOA and PFOS, the most common PFAS compounds, at 4 parts per trillion. The rule is expected to be final in early 2024.

- Since most of the water systems in the county tend to regularly rely on a high percentage of available capacity, taking any sources offline will impact available capacity.
- Hazen identified potential PFAS sources, which could include fire training facilities, fire stations, airports, landfills, and others. If a buffer were placed around these sources, some municipal wells would be considered at higher risk for PFAS contamination.
- PFAS treatment options in drinking water are limited, but there are opportunities for optimized implementation. Mitigation alternatives include well management, treatment at water treatment plants, and treatment at the source. Hazen discussed approaches for evaluating management and treatment options. The primary options include granular activated carbon (GAC), ion exchange, and reverse osmosis (RO)/nanofiltration. Hazen suggested benchmarking treatment conditions.
- Hazen also discussed how to determine cost of compliance with EPA's new rule and the associated timeline. Choice of treatment approach and costs vary depending on the option and the individual system. Hazen shared information on Peoples Water in Florida as a case study.

Reference/Attachment: PFAS Workshop

- *Carroll County WRCC: PFAS Implications for Municipalities*

4. Water Resources Element (WRE 2024) Update – Chris Heyn

- Task 1.2: Automation of Portions of Buildable Land Inventory model: Completion is anticipated for early September.
- Task 2: Groundwater Allocability: Hazen is working on technical memo and will provide a revise document soon.
- Task 3: Emerging Contaminants: Hazen will take any feedback provided at WRCC meeting regarding PFAS topic and incorporate to technical memo. The technical memo is expected in early August.
- Task 4: MDE TIPP Spreadsheet Comparison: Hazen is comparing the results of the MapShed model used previously for the TMDL implementation plans with the results of one of the watersheds using MDE's TMDL Implementation Progress and Planning tool. A technical memo will be provided in August.
- Task 5: Climate Change Impacts: Hazen is working on evaluating climate change impacts as they relate to water resources. A draft technical memo is due in August.
- Task 6: Update 2010 WRE Supporting Documents: Hazen will update the supporting documents used to prepare the 2010 WRE. This includes the capacity and demand information used to identify needs, challenges, and recommendations regarding shorter-term and long-term water supply and wastewater. Brenda Dinne is meeting with each municipality/system to review the completed workbooks, which now include demand information, prior to providing them to Hazen. The name of the workbooks has been changed to "Capacity & Demand" rather than "Capacity Management Plan" to help avoid confusion regarding the purpose of these workbooks. They are for planning purposes only and not intended to be submitted to MDE.

Reference/Attachment:

- *N/A*

5. Municipal Stormwater Projects Update – Janet O'Meara

Janet O'Meara provided an update on the municipal stormwater restoration projects.

Reference/Attachment:

- *Municipal Project Status*

6. Other

- Water Conservation: Mr. Swanson shared that the Mayor of Mt. Airy is now posting videos on Facebook about water conservation.
- 20SW Facilities: Ms. Hirt reminded those who need to apply for a 20SW permit that the Notice of Intent (NOI) is due at the end of the month. If the Stormwater Pollution Prevention Plan (SWPPP) is not completed, it can be submitted separately.
- 2022 NPDES Annual Report: Ms. O'Meara stated that MDE's comments on the 2022 annual report were positive.
- 2023 NPDES Annual Report: Ms. Hirt indicated emails will go out next week or two for updating information.

7. Adjournment

The meeting adjourned at 3:56 PM. The next monthly meeting is scheduled for Wednesday, August 23, 2023, at 2:30 PM.

MEETING ADJOURNMENT: Motion was made by Mayor Perry Jones and seconded by Alex Perricone to adjourn the July 26, 2023, meeting. Motion carried.

Upcoming Meetings:

- ☐ *Regular Monthly Meeting – Wednesday, August 23, 2023*

MUNICIPAL STORMWATER PROJECT STATUS

July 26, 2023

FUTURE PROJECTS:

Michael's Property (Hampstead) – Project is on hold until Town has obtained approval from property owners to move forward.

Meadow Ridge Basin 2 (Westminster) – Retrofit of existing facility to provide water quality through a surface sand filter. This site is adjacent to the pump station at the edge of the City limits. The County has begun sending out RFPs under the new term contract. We are expecting to send this one out within the next few months.

Hampstead Valley 2/3 (Hampstead) – Hampstead Valley facilities 2 and 3 will be retrofitted as a stream restoration project to decommission Sycamore Drive as a roadway embankment. The design will include a stream restoration beginning immediately downstream of the proposed Hampstead Valley 1 facility and continue to Sycamore Drive.

CONCEPT DESIGN:

Hampstead Valley 1 (Hampstead) – Retrofit of existing detention basin to a surface sand filter. Site is located just south of Lower Beckleysville Road near a production well. CLSI is currently working on resubmitting a concept plan of a triple facility design. New Dam Safety requirements have gone into effect. These requirements include additional modeling, which may affect the current concept design.

Manchester East (Manchester) – We are looking into opportunities for a new stormwater facility north of Manchester Valley High School, adjacent to the pump station. We have awarded this project to CLSI. They are getting started with a design for a new surface sand filter and potential for drainage improvement at the upstream end of the stormdrain network.

New Windsor Wetland (New Windsor)- A new wetland facility is proposed adjacent to the Maryland Midland Railroad tracks and Dickenson Run. The proposed improvements include removing the existing inlet adjacent to the intersection of Water St and Church St, replacing it

with a diversion structure that will route the 1-year storm discharges to the proposed wetland facility. We are working through the design with the engineer for a structure to balance the facility on both sides of the sewer main. A concept plan was submitted July 12th for review.

Public Safety Training Center (Westminster Well)- A retrofit for the Public Safety Training Center pond is in progress for the facility design and PFAS remediation. WRA is finalizing the concept plan for the surface sand filter this week. Tetra Tech will provide guidance for the PFAS remediation. A concept plan was submitted on July 13th for review.

PRELIMINARY DESIGN:

Hampstead Valley 4 (Hampstead) – A new surface sand filter and stream restoration project is proposed between Century Street and Downhill Trail. Culverts at Downhill Trail require realignment into the HOA parcel for dam breach approval. A preliminary submittal was reviewed by stormwater and sent back with comment.

Roberts Field Wet Facility (Hampstead) – Retrofit of wet pond to new hybrid wet pond/submerged gravel wetland. The recent concept submittal was approved with comments from the Town and Stormwater Management. Wallace Montgomery & Associates (WMA) is beginning the preliminary phase of design.

FINAL DESIGN:

CONSTRUCTION:

North Carroll Library (Hampstead) – As-built has been approved.

PLANNING PROJECTS:

Little Pipe Creek Restoration Opportunities – The County has executed the grant agreement with the National Fish and Wildlife Foundation (NFWF). CWP has developed an outline for identifying priority restoration areas, this is currently being reviewed internally. CWP and County staff went out together for an assessment of Little Pipe watershed in late June.

TREE PLANTING PROJECTS:

All the municipal plantings have completed their maintenance period and are now the responsibility of the municipalities. Please make sure that these areas are being mowed at least three (3) times per season.

Hazen



Carroll County WRCC: PFAS Implications for Municipalities

July 26, 2023

Agenda

- Introductions
- PFAS Regulatory Overview
- Potential PFAS Implications
- PFAS Mitigation and Treatment
- Determining Cost of Compliance and Case Study
- Q&A

Regulatory Review

Proposed PFAS Rule

The proposed rule set MCLGs and MCLs for PFOA and PFOS, and took a risk-based approach to regulating 4 additional PFAS compounds:

- PFNA
- PFHxS
- PFBS
- GenX


Compound	Proposed MCLG	Proposed MCL (enforceable levels)
PFOA	Zero	4.0 parts per trillion (also expressed as ng/L)
PFOS	Zero	4.0 ppt
PFNA	1.0 (unitless) Hazard Index	1.0 (unitless) Hazard Index
PFHxS		
PFBS		
HFPO-DA (GenX Chemicals)		

$$PFAS\ Hazard\ Index\ MCL = \left[\frac{HFPO-DA_{water}}{10 \frac{ng}{L}} \right] + \left[\frac{PFBS_{water}}{2,000 \frac{ng}{L}} \right] + \left[\frac{PFNA_{water}}{10 \frac{ng}{L}} \right] + \left[\frac{PFHxS_{water}}{9 \frac{ng}{L}} \right]$$

Implications for Municipalities

Water Demand and Capacity

- Water supply capacity exceeds average daily demand for all County municipalities, but some regularly rely on all or nearly all the available capacity.




Data source: Carroll County Water and Sewer Master Plan, 2023 Triennial Update

Water Demand and Capacity

Percentage of Capacity Used

- Water supply capacity exceeds average daily demand for all County municipalities, but some regularly rely on all or nearly all the available capacity.




Data source: Carroll County Water and Sewer Master Plan, 2023 Triennial Update

Water Demand and Capacity

Projected Percentage of Capacity Used

- The percentage of water capacity used is expected to increase for most County municipalities over the next decade.





Data source: Carroll County Water and Sewer Master Plan, 2023 Triennial Update

Potential PFAS Sources

Potential PFAS sources in the County include:



- Fire training facilities
- Fire stations
- Airports
- Military sites and installations
- Landfills
- Manufacturing facilities
- Wastewater treatment plants



Likelihood of PFAS Issues

Proximity of Potential PFAS Sources to Production Wells


- Spatial buffer analysis to identify production wells that are more likely than others to have PFAS issues
- Buffers increase from 500 feet radius to more than 2,500 feet radius
- Results can help prioritize monitoring and identify wells and municipalities that may be affected by PFAS contamination



Likelihood of PFAS Issues

500 ft radius

Municipality	Well Name	PFAS Source Type
Pleasant Valley	Fire Station	Fire Station
Hampstead	PW-26	Wastewater
Union Bridge	PW-3	Fire Station




Production Wells		PFAS Source	
● Well Online		▲ Fire Station	
		● Wastewater	

Likelihood of PFAS Issues

1,000 ft radius

Municipality	Well Name	PFAS Source Type
Union Bridge	PW-1	Fire Station, Wastewater
Pleasant Valley	PW-1A	Wastewater
Hampstead	PW-23	Wastewater
Union Bridge	PW-3	Wastewater
Mount Airy	PW-6	Wastewater
Westminster	PW-8 (Vo-Tech)	Fire Training Facility








Production Wells	PFAS Source
Well Online	Fire Station
Offline due to PFAS	Fire Training Facility
	Wastewater




Likelihood of PFAS Issues

1,500 ft radius

Municipality	Well Name	PFAS Source Type
Westminster	Koontz Creamery	Fire Station
Hampstead	PW-24	Fire Station, Manufacturing
Hampstead	PW-25	Fire Station, Manufacturing
Hampstead	PW-27	Wastewater
Westminster	PW-4 (Air Bus. Cent.)	Airport
New Windsor	Roops Meadow Spring	Manufacturing

Production Wells		PFAS Source	
	Well Online		Airport
	Offline due to PFAS		Fire Station
			Fire Training Facility
			Manufacturing
			Wastewater



Potential PFAS Implications on Growth and Development

Known PFAS Contamination

- Three wells currently offline due to PFAS are close to fire stations or fire training facilities

Municipality	Well Name	Potential PFAS Source	Buffer Distance (ft)
Hampstead	PW-24	Fire Station	1,500
Hampstead	PW-25	Fire Station	1,500
Westminster	PW-8 (Vo-Tech)	Fire Training Facility	1,000

Potential PFAS Implications on Growth and Development



Potential PFAS Contamination from Fire Stations

Municipality	Well Name	Buffer Distance (ft)	% of Average Daily Use	Notes
Hampstead	PW-28, PW-29	2,500	45%	Determined from permitted daily use
Manchester	Holland Dr. Well	2,500	5%	
	Walnut St. Spring	2,500	15%	Determined from Walnut St. spring storage capacity
	Walnut St. Well	2,500	2%	
Mount Airy	PW-5	2,000	19%	Well Field 5 & 6
New Windsor	Roops Meadow Spring	2,000	80%	Dennings Well, Main Spring, Roops Meadow Spring
Pleasant Valley	Fire Station	500	-	Pumping data unavailable
Taneytown	PW-8	2,000	8%	
Union Bridge	PW-1	1,000	24%	
	PW-3	500	18%	Not in use
Westminster	Koontz Creamery (stream augmentation)	1,500	-	Stream augmentation


Mitigation Options

PFAS Treatment Options in Drinking Water

Limited effective technologies...



But opportunities for optimized implementation



Mitigation alternatives


Well Management




Treatment at WTPs



Treatment at the Source




Approach For Evaluating Management and Treatment Options



Step 1: Can WELL MANAGEMENT achieve PFAS Targets

- Use Mass Balance Model of the Well Supply System to define impacts of well operations on observed concentrations at the WTPs
- Study effect of shutting down wells, minimizing use of wells, paired well operation, etc.


Approach For Evaluating Management and Treatment Options



Step 2: Understand impacts of WTP treatment on concentrations at WTP

- Is treatment at the WTPs capable of meeting PFAS targets?
 - PFOA, PFOS < 4 ppt (Draft MCL)
 - HI < 1

Approach For Evaluating Management and Treatment Options



Step 3: Understand impacts of wellfield treatment on concentrations at WTP

- Is treatment at individual wells/wellfields capable of meeting PFAS targets?




Currently Available Treatment Solutions to Address PFAS in Drinking Water

Even “Advanced” technologies comes up short sometimes




Technology	Benefits	Drawbacks
GAC	<ul style="list-style-type: none"> • Proven PFOA/PFAS removal • Removal of other chemicals (e.g., VOCs, EDCs, PPCPs) • DBP precursor reduction • Can be reactivated/reused 	<ul style="list-style-type: none"> • Carbon replacement costs can be costly especially for short chains • Need to consider breakthrough time and regeneration cycles • Spent Material Disposal concerns (RCRA)
Ion Exchange	<ul style="list-style-type: none"> • Proven PFOA/PFAS removal • May be more effective for removal of some short chain PFASs 	<ul style="list-style-type: none"> • Single use of resin cannot be regenerated • Competing ions may affect performance or require pre-treatment (TOC, Fe/Mn) • Limited removal of other contaminants • Spent Material Disposal concerns (RCRA)
Reverse Osmosis / Nanofiltration	<ul style="list-style-type: none"> • Removal of most PFAS • Removal of additional contaminants • DBP precursor reduction • Softening 	<ul style="list-style-type: none"> • Brine management • Costly compared to other options

PFAS Treatment Approaches

		Pros	Cons	
	Adsorption	Ease of Implementation, Cost Effectiveness	Treatment Effectiveness Varies with WQ and PFAS	} PFAS Separation
	High Pressure Membranes	Removal of Legacy & Next Generation PFAS	Cost and Concentrate Disposal	
	PFAS Destruction	Complete Mineralization of PFAS	Cost and Maturity	

Summary of PFAS removals for various treatment processes

		Removal <10%	Removal 10-90%	Removal > 90%						
	M.W. (g/mol)	AER	COAG/DAF	COAG/ FLOC/ SED/ G-or M-FIL	AIX	GAC	NF	RO	MnO4, O3, ClO2, Cl2, CLM, UV, UV-AOP	
PFBA	214	Assumed	Assumed							
PFPeA	264									
PFHxA	314									
PFHpA	364									
PFOA	414									
PFNA	464		Unknown		Assumed	Assumed				
PFDA	514		Unknown		Assumed	Assumed				
PFBS	300									
PFHxS	400									
PFOS	500									
FOSA	499	Unknown	Unknown		Unknown	Assumed	Unknown	Assumed	Unknown	
N-MeFOSAA	571	Assumed	Unknown		Assumed	Assumed	Assumed		Unknown	
N-EtFOSAA	585		Unknown		Assumed	Assumed	Assumed		Unknown	



Removal of PFAS from source waters depends on target, concentration, raw water quality and other variables (WaterRF 4322)

Benchmarking Treatment Conditions

Adsorption Systems

Adsorbent	Adsorber Configuration	EBCT (Total, min)	Flow Rate (MGD)	Spent Media Disposal	Interest Rate	Lifespan
GAC	Lead/Lag	20	1.5, 10	Off-Site Regeneration	5%	30 years
IX Resin	Lead/Lag	4	1.5, 10	Throwaway, Non-Hazardous		

Membrane Systems

Membrane	Flow Rate (MGD)	Background Water Quality	Flux (gfd)	Concentrate Disposal	Interest Rate	Lifespan
NF	1.5, 10	High/Low	19 _{High} / 17 _{Low}	Ocean Outfall/POTW	5%	30 years
RO	1.5, 10	High/Low	19 _{High} / 17 _{Low}	Ocean Outfall/POTW		
Constant flux operation contingent on background water quality selection						

Determining Cost of Compliance

How to determine Cost of Compliance?



1. Understand the potential impacts of regulatory action (which compounds, which technologies, residuals?)
2. Understand feasibility and viability of treatment technologies (ie., IX resin is not suitable for gravity contactors)
3. Cost of compliance is a function of capital and operating and maintenance costs
 - Capital costs are escalating rapidly
 - O&M is critically important to cost of compliance
 - Media and residuals disposal costs are in flux
4. How to pay for the upgrades?

Cost Modeling Strategy


Today



Class V Cost Curves available

Class IV Estimates take a little longer, and may immediately be obsolete

Tomorrow



O&M is a function of:

- Media replacement (IX, GAC)
- Pumping Costs
- Brine / media disposal


The Future



The future can be impacted by:

- Short-chain PFAS regulations
- Cost Uncertainty
- Supply-chain issues
- Disposal of Media or Residuals

Cost of Adsorptive Treatment



- IX and GAC cost curves look very similar.
- At changeout times exceeding 6 months, IX resin may become more cost effective.
- Cost curves can be adapted for a variety of operation conditions, adjustments of appropriate spent media disposal costs remains ongoing.


Adsorbent	Adsorber Configuration	EBCT (Total, min)	Flow Rate (MGD)	Spent Media Disposal
GAC	Lead/Lag	20	1.5	Off-Site Regeneration
IX resin	Lead/Lag	4	1.5	Throwaway, Non-Hazardous

Capital Cost Estimates Developed from Projects Around the Country

Today's Options



GAC Cost Curve for PFAS projects



Additional Cost Modeling Tools to Expand capabilities

Working towards tomorrow's

Water Research Foundation Project 4913: Investigation of Treatment Alternatives for Short-chain PFAS



THE
Water
Research
FOUNDATION

Hazen

NC STATE
UNIVERSITY

AMERICAN WATER



CDM
Smith
listen. think. deliver.




Work Breakdown Structure (WBS) Models Previously Developed by EPA

STEP 5		Generate Results	Resulting Costs (in year 2020 dollars, see OUTPUT sheet for details)
Results are ready (no need to click button)			Direct Capital Cost: \$4,431,280 Total Capital Cost: \$6,716,378 Annualized Capital Cost: \$368,444 per year (over 30 years at 4%) Annual O&M Cost: \$557,512 per year Total Annualized Cost: \$346,356 per year (4% capital, 53% O&M)
MANUAL INPUTS <i>Cells in gold are required; cells in blue are optional</i>			
Design Flow (including bypass)	10,000 MGD	Select units	
Average Flow (including bypass)	10,000 MGD		
For information: Treatment system design flow	10,000 MGD		
Bypass design flow	0,000 MGD		
		System size inputs OK	Current bypass percentage is 0%. Go to Critical Design Assumptions (link below) to change this value. Adjust bypass percentage
Select carbon life input type	carbon life value- bed volumes	<- pick one	Guidance: Carbon life is best determined by pilot or RSSCT tests. Use theoretical calculation methods (e.g., Freundlich isotherms) only in the absence of such data for initial assessment of carbon life and suitability of GAC for treatment. See Freundlich isotherm reference data See PFAS breakthrough reference data
Carbon life	300000	bed volumes	
no additional input required		not required	
no additional input required		not required	
no additional input required		not required	
For information: Carbon Life	69.5	months at average flow	Important: carbon life calculation assumes bed volumes are based on EBCT per vessel Carbon life reflects time between change outs of the lead vessel
		Carbon input OK	
Contaminant removal input type	EBCT	<- pick one	Guidance: EBCT is best determined by pilot tests, but may be calculated for radon if a steady state rate constant (Kss) is available. Use the theoretical calculation method for radon only in the absence of pilot data for initial assessment of EBCT and suitability of GAC for treatment. Consider multiple vessels in series for long EBCTs (> 10 minutes)
Total Theoretical Empty Bed Contact Time (EBCT)	20	minutes	
no additional input required		not required	
no additional input required		not required	
Minimum number of contactors in series (i.e., parallel or series operation)	2	<- enter 1 for parallel, 2 or more for series	
For information: EBCT	20.0	minutes at design flow	
EBCT per contactor	10.0	minutes at design flow	
		Contaminant removal inputs OK	
Pressure Vessels <i>The next four inputs may be entered manually, or calculated with AutoSize button. All other gold inputs must be complete before AutoSizing.</i>			
Auto Size Pressure Vessels	Bed depth	7	feet
	Vessel geometry	upright	<- pick one
	Height (straight)	11	feet
	Diameter	13	feet
For information: Number of treatment trains	10	trains	
Number of operating vessels	20	units	
Total vessels (incl. redundancy, below)	23	units	
			Guidance: Typically upright, although larger systems (e.g., greater than 2,000 gpm) might use horizontal vessels Guidance: Typically up to 14 feet for upright vessels, 20 to 40 feet for horizontal vessels Guidance: Typically 1.5 to 14 feet for upright vessels, 10 to 14 feet for horizontal vessels

O&M Costs are crucial to understanding viability of treatment technology

Today's cost estimates

- IX models produce accurate cost estimates. GAC estimates were lacking.



A		B	C	D	E	F	G	H	I	J
1		Instructions:	Please provide as much information as possible in the table below.							
2			Blue background data is critical for PFAS rating							
3			Green background data will be assumed ND for PFAS rating							
4			Do not Modify the Sheet as it will create errors when processing							
5		rev17Sep2021FB								
7		Information Requested for PFAS Treatment						Non-PFAS	Ratings for BV based on resin volume	
8		Customer:		Date rated:			goals	in lead vessel with PFAS break as		
9		Project:		Sample:				indicated below		
10		Description	Units	Influent Water				PFAS Break	PFAS Break	
11				Min	Avg	Max		measured ex	measured ex LAG	
12		Operational Flow Rate	gpm					LEAD Vessel at:	Vessel at:	
13		Operational Schedule	hour/day							
14		Daily Volume (average)	Gallons							
15	→	Sulfate	mg/L (ppm)							
16	→	Nitrate (as N)	mg/L as N							
17	→	Nitrate (as NO3)	mg/L as NO3							
18	→	Alkalinity (as CaCO3)	mg/L as CaCO3							
19	→	Chloride	mg/L (ppm)							
20		Fluoride	mg/L (ppm)							
21		Perchlorate	µg/L (ppb)				(e.g. < 4 ppb)			
22		Arsenate (As (V))	µg/L (ppb)							
23		Hexavalent chromium (chromate) Cr(VI)	µg/L (ppb)							
24		Uranium	µg/L (ppb)							
25		Calcium (as CaCO3)	mg/L as CaCO3							
26		Magnesium (as CaCO3)	mg/L as CaCO3							
27		Sodium	mg/L (ppm)							
28		Potassium	mg/L (ppm)							
29		Iron	mg/L (ppm)							
30		Manganese	mg/L (ppm)							

PFAS Spent Adsorbent Disposal


Costs and Availability Changing Rapidly



Landfilling:

Subtitle D \$50-\$100 per ton

Subtitle C \$300-\$500 per ton



Incineration:

MSW Incinerator \$200-\$300 per ton

HW Incinerator \$1,200+ per ton



Electrochemical Oxidation, Super Critical Water Oxidation, Plasma, Hydrothermal Liquefaction, Others
Costs not well developed

Case Study – Peoples Water in Florida - ~1.5 MGD Well




Figure 5-1: Proposed Well 5 GAC Process Flow Diagram

Table 5-2: Hazen and Calgon Projected GAC Replacement

Goal	Bed Volume to PFAS Breakthrough	GAC Changeout Frequency*
Calgon carbon Corporation Model	105,000	1.9 years
Hazen GAC Model	83,000	1.5 years

*: Changeout frequency is assumed to be based on continuous operation of Well 5 at 1,000 gpm.




Figure 5-2: Well 5 Estimated Site Layout for GAC

Case Study – Peoples Water in Florida - ~1.5 MGD Well

Table 5-3: GAC Capital Cost Estimate

Description	Cost
General Conditions	\$126,000
Civil/Site Work	\$150,000
Mechanical*	\$750,000
GAC Vessels	\$600,000
GAC Media	\$150,000
Structural	\$150,000
Architectural	NA
HVAC/Plumbing	NA
Electrical	\$105,000
Instrumentation & Controls	\$105,000
Subtotal	\$1,386,000
Design Contingency (30%)	\$416,000
Contractor Overhead, Profit & Fee (25%)	\$347,000
Escalation (at 3%-5% Annually)	\$69,000
Bond and Insurance (3%)	\$42,000
TOTAL	\$2,260,000

*: Summation of GAC Vessels and GAC Media




Figure 5-3: Hazen Predicted PWSC Well 5 GAC PFAS Breakthrough Versus Bed Volumes Processed.

Table 5-6: Calgon GAC Cost Comparison with Purolite AdEdge IX System

Cost Metric	GAC (Section 5.1)		IX (Section 5.2)	
	Low Estimate	High Estimate	Low Estimate	High Estimate
Capital Cost	\$2,260,000		\$2,281,200	
Annual O&M	\$8,784.84	\$109,836.49	\$15,523.12	\$153,419.61
Cost Per Gallon(per 1,000 gallons)	\$0.21		\$0.29	
Net Present Value *	\$2,390,696.19	\$3,894,089.63	\$2,512,144.88	\$4,563,696.38

*: 3% escalation, annualized over 20 years

Q&A